

汕尾德昌电子有限公司
排放口出水铜含量检测记录表

RN:CPS-0418-7 A

注：检查频率 1次/周

日期	达标排放标准 <0.5mg/L	检测结果 mg/L	检查人	备注
20170106	<0.5	0.024	10675	
20170113	<0.5	0	10675	
20170120	<0.5	0.038	10675	
20170210	<0.5	0.126	10675	
20170217	<0.5	0.18	10675	
20170224	<0.5	0	10675	
20170303	<0.5	0.212	10675	
20170310	<0.5	0.058	10675	
20170317	<0.5	0.201	10675	
20170324	<0.5	0.109	10675	
20170331	<0.5	0.157	10675	
20170407	<0.5	0	10675	
20170414	<0.5	0.085	10675	
20170421	<0.5	0.052	10675	
20170428	<0.5	0.112	10675	
20170512	<0.5	0.015	10675	
20170519	<0.5	0.047	10675	
20170526	<0.5	0.136	10675	
20170602	<0.5	0.211	10675	
20170609	<0.5	0.165	10675	
20170616	<0.5	0.208	10675	
20170623	<0.5	0.084	10675	
20170630	<0.5	0.024	10675	